

[Try Another Page](#) | [Return to Search Page](#)

20.50.10.06

.06 Safety Standards and Controls for Net Energy Metering.

An electric generating system used by an eligible customer-generator for net energy metering shall meet all applicable safety and performance standards incorporated by reference in COMAR 20.50.02.02.

[Try Another Page](#) | [Return to Search Page](#)

20.50.02.02

.02 Acceptable Standards.

Unless otherwise specified by the Commission, the utility shall use the applicable provisions in the latest revised version of the incorporated by reference publications listed below as standards of accepted good engineering practice in this subtitle:

- A. National Electrical Safety Code, ANSI C2—2002;
- B. National Electrical Code, ANSI/NFPA 70—2005;
- C. American National Standard for Electric Meters — Code for Electricity Metering, ANSI C12.1—2001;
- D. American Standard Requirements, Terminology and Test Code for Instrument Transformers, ANSI/IEEE C57.13—1993;
- E. Standard for Interconnecting Distributed Resources with Electric Power Systems, IEEE Standard 1547—2003;
- F. Conformance Test Procedures for Equipment Interconnecting Distributed Resources with Electric Power Systems, IEEE Standard 1547.1—2005;
- G. NEMA Standards Publication TP 1—2002; and
- H. Guide for Electric Power Distribution Reliability Indices, IEEE Standard 1366—2003, 4.5 Major event day classifications.