

**Town of Williamsport
Request for Proposals
2022-11 Paving of Town Hall Parking Lot**



SCOPE OF ADDENDUM #1 – October 6, 2022

The following items constitutes the Town's response to questions presented during the Pre-Bid Meeting held on Tuesday, October 4, 2022. At 2:00pm. These items must be considered and addressed within submitted bids. Bid submissions not incorporating these addenda will be subject to rejection.

Revision 1; Section I, Paragraph 2: the estimated measurements for the total area will be 111 feet by 33 feet with a 3" overlay after completing necessary sub-base work.

Revision 2; Section I, Paragraph 2: subbase will include 2½" of 19mm stone and 1½" of SM 9.5 finish course.

Revision 3; Section I, Paragraph 2: SA 64-22 will be utilized to seal all joints.

Revision 4; Section III, Item A: a unit price for white paint and a unit price for yellow paint must be submitted at a cost per linear foot. This may be indicated by writing the per unit pricing after the salutation of this addendum.

Revision 5; Section III, Item A: a unit price for blue paint per linear foot and a cost for painted handicap placard must be submitted as a per unit (one blue/white painted placard) must be submitted. This may be indicated by writing the per unit pricing after the salutation of this addendum.

Revision 6; The project area is being expanded to include the parking area and alley in front of the storage garages, the total area is estimated to be 10' by 87' in the parking area and 12' by 87' for the alley.

Revision 7; Clarification on question regarding alley specifications: the Town does not have authorized specifications on alleyways; however, it will be expected that the sub-base is properly configured to create a channel in the center for the purpose of stormwater flow and the parking area is angled to move the water to this channel. The channel will move water from the alley way onto West Salisbury Street.


Revision 8; Section III, Item F: remove the entirety of this item.

Revision 9; A "per cubic foot" unit price of subbase and overlay as outlined in Item 1 and Item 2 of this addendum must be included in the submitted bids. This may be indicated by writing the per unit pricing after the salutation of this addendum.

Please send all questions regarding this RFP & Addendum to townmanager@williamsportmd.org. The Town's response to all submitted questions pertaining to the Scope of Work will be addressed by e-mail (BCC) to all those who have provided information to the Town. The response will also be advertised on the Town's website under "*Request for Proposals*" to ensure any potential contractor wishing to submit a bid, but did not provide their information to the Town, has access to this information.

******* A signed copy of this addendum must accompany your bid submission *******

Respectfully,



Chad P. Rooney, MBA, CBO
Town Administrator

Submitting Contractor: _____

Authorized Representative Name: _____

Date: _____

Authorized Representative Signature