

**Town of Williamsport  
Request for Proposals  
2023-02  
Billy Doub Park Sidewalk Project**



**SCOPE OF ADDENDUM #3 – February 17, 2023**

The following items constitutes the Town’s response to questions presented by one of the potential companies submitting a bid. These items must be considered and addressed within submitted bids. Bid submissions not incorporating these addenda will be subject to rejection.

Revision 9: Remove and reject Revision 5 and replace it with the following: Expansion joints will be no further than 25 feet apart.

**\*\*\*\*\* A signed copy of this addendum must accompany your bid submission \*\*\*\*\***

Respectfully,

A handwritten signature in black ink, appearing to be "Chad P. Rooney".

Chad P. Rooney, MBA, CBO  
Town Administrator

Submitting Contractor: \_\_\_\_\_

Authorized Representative Name: \_\_\_\_\_

Date: \_\_\_\_\_

\_\_\_\_\_  
Authorized Representative Signature